

		330/110kV Tartu-Sindi õhuliini ehitus										KPL1010-K2.2-T6.1TJ					
		II ehitusetapp, Oiu – Viljandi										7.12.2012					
												Lk1/5					
elering ÜHENDAME ENERGIAD																	
EMPOWER																	
Masti tähis		Armatuuri tabel															
Nurk																	
Masti nr																	
103Y	AT2Y-26/33,4	P. 1,06°	2			3	1		3	27	6	2	24	18	12	2	21
104Y	S2G-27/35		3				3			21		1			12	2	21
105Y	S2G-27/35		3				3			21		1			12	2	21
106Y	S2G-25/33		3				3			21		1			12	2	21
107Y	S2G-25/33		3				3			21		1			12	2	21
108Y	S2G-28/36		3				3			21		1			12	2	21
109Y	AT2Y-23/30,4	P. 16,72°	2			6			6	26	6	2	12	18	12	2	21
110Y	S2G-25/33		3				3			21		1			12	2	21
111Y	S2G-25/33		3				3			21		1			12	2	21
112Y	S2G-25/33		3				3			21		1			12	2	21
113Y	S2G-25/33		3				3			21		1			12	2	21
114Y	S2G-25/33		3				3			21		1			12	2	21
115Y	AS2G-27/35	V.1,99°	3				3			21		1			12	2	21
116Y	S2G-27/35		3				3			21		1			12	2	21
117Y	AT2G-23/30	V.39,47°	3			6	3		6	21		2	12	18	12	2	21
118Y	AT2Y-20/27,4	P. 34,85°				6	2		6	30	6	2	12	18	12	2	18

		330/110kV Tartu-Sindi õhuliini ehitus II ehitusetapp, Oiu – Viljandi							KPL1010-K2.2-T6.1TJ		
									7.12.2012		
									Lk2/5		
elering ÜHENDAME ENERGIAD	EMPOWER								vibr_ Summutavad dist_ Hoidikud		
								330 3D	18		
								Vibr summutid FE67 VD-Fe	2		
								Võr summitid 110 kV juhtmele VD-1	12	2	18
								Paraleelklemm PGC 402-AI1/52-ST1A			
								Paraleelklemm PGC 243-AI1/39-ST1A			
								Fe67 tõmbekett Fe-T			
								Fe67 kandekett Fe-K	1		
								Dist hoidikud 330 kV looka 3D-L			
								Dist hoidikud 110 kV juhtmele 1D	18		
								330 kV tõmbekett (2xU210) 3T2U210			
								330 kV kandekett nurga- kandemastile 15...20 kraadi			
								330 kV kandekett (1xU160) 3K1U160	3		
								330 kV ablikandekett 3K-A			
								110 kV tõmbekett (1xU160) 1T1U160			
								110 kV topeltõmbekett (2xU120) 1T2U120			
								110 kV topeltkandekett (2xU70) 1K2U70			
								110 kV kandekett nurga- kandemastile 15...20 kraadi			
								110 kV kandekett (1xU70) 1K1U70	3		
								Nurk			
Masti nr	Masti tähis										
119Y	S2G-22/30										
120Y	S2G-22/30		3								
121Y	AT2Y-20/27,4	P. 49,91°									
122Y	S2G-28/36		3								
123Y	S2G-25/33		3								
124Y	S2G-26/34		3								
125Y	S2G-22/30		3								
126Y	AT2G-17/24	V.42,88°	3			6	2				
127Y	S2G-27/35		3								
128Y	AT2G-23/30	V.31,74°	3			6	3				
129Y	S2G-27/35		3								
130Y	S2G-22/30		3								
131Y	S2G-24/32		3								
132Y	S2G-25/33		3								
133Y	AT2G-23/30	P. 31,28°	3			6	3				
134Y	S2G-27/35		3								
135Y	S2G-28/36		3								

		330/110kV Tartu-Sindi õhuliini ehitus II ehitusetapp, Oiu – Viljandi										KPL1010-K2.2-T6.1TJ	
		7.12.2012											
		Lk3/5											
Masti nr	Masti tähis	Nurk	3	3	3	3	3	3	3	3	3	3	3
136Y	AT2G-26/33	V.16,76°											
137Y	AT2Y-20/27,4	P. 32,37°	2			6	1		6	26	6	2	12
138Y	AT2G-17/24	V.15,43°		3					3		21		2
139Y	S2G-25/33		3					3			21		2
140Y	S2G-27/35		3					3			21		2
141Y	S2G-22/30		3					3			21		2
142Y	S2G-23/31		3					3			21		2
143Y	S2G-24/32		3					3			21		2
144Y	AT2Y-20/27,4	V.17,65°	2			6	3		6	26	6	2	12
145Y	S2G-29/37		3					3			24		2
146Y	S2G-25/33		3					3			24		2
147Y	S2G-30/38		3					3			24		2
148Y	AT2G-23/30	V.37,18°	3			6	3		6	24		2	12
149Y	S2G-25/33		3					3			24		2
150Y	S2G-26/34		3					3			24		2
151Y	AT2G-26/33	P. 61,96°	3			6			6	21		2	12
152Y	S(AT)2G-15/23		3			6			6	18		2	12

		330/110kV Tartu-Sindi õhuliini ehitus II ehitusetapp, Oiu – Viljandi										KPL1010-K2.2-T6.1TJ			
												7.12.2012			
			Lk4/5												
Masti nr	Masti tähis	Nurk										vibr_ Summutavad dist_ Hoidikud	330 3D	18	
153Y	S2G-30/38											Vibr summrid FE67 VD-Fe		2	
154Y	AT2Y-20/27,4	V.53,96°	3			6	2		6	24	6			12	2 18
155Y	AS2G-22/30	V.2,75°	3				3			18		1		12	2 18
156Y	AT2Y-20/27,4	P. 21,17°	3			6	1		6	27	6		2	12 18	
157Y	S2G-27/35		3					3			12		1		12 2 12
158Y	AS2G-18/26	P. 2,71°	3					3			18		1		12 2 18
159Y	S2G-18/26		3					3			15		1		12 2 15
160Y	S2G-18/26	P. 1,31°	3					3			15		1		12 2 15
161Y	S2G-26/34	V.0,94°	3					3			21		1		12 2 21
162Y	S2G-28/36		3					3			21		1		12 2 21
163Y	S2G-27/35		3					3			21		1		12 2 21
164Y	AT2Y-26/33,4	V.4,00°	3			6			6	27	6		2	12 18	12 2 21
507 16	TAS-30	P. 10,86°							3				1		1 3
05B 10	5E-12		3			3	3						12		12
166Y	AT110-2-11					3	6						3		

elering ÜHENDAME ENERGIAD	330/110kV Tartu-Sindi õhuliini ehitus II ehitusetapp, Oiu – Viljandi	KPL1010-K2.2-T6.1TJ	
		7.12.2012	Lk5/5
EMPOWER		vibr_ Summutavad dist_ Hoidikud 330 3D	1278
		Vibr summutid FE67 VD-Fe	125
Masti tähis	Nurk	Viir summrid 110 kV juhtmele VD-1	756
Masti nr		Paraleelklemm PGC 402-AI1/52-ST1A	288
		Paraleelklemm PGC 243-AI1/39-ST1A	216
		Fe67 tömbekett Fe-T	40
		Fe67 kandekett Fe-K	44
		Dist hoidikud 330 kV looka 3D-L	54
		Dist hoidikud 110 kV juhtmele 1D	1337
		330 kV tömbekett (2xU210) 3T2U210	96
		330 kV kandekett nurga-kandemastile 15...20 kraadi	6
		330 kV kandekett (1xU160) 3K1U160	132
		330 kV ablikandekett 3K-A	27
		110 kV tömbekett (1xU160) 1T1U160	102
		110 kV topelttömbekett (2xU120) 1T2U120	6
		110 kV topeltkandekett (2xU70) 1K2U70	
		110 kV kandekett nurga-kandemastile 15...20 kraadi	6
		110 kV kandekett (1xU70) 1K1U70	173